

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN436		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SEVERIN, ERIC					Phone # (218)590-7140		1. Well Location				Fire # (if avail.)				
Mailing Address 11350 S TWIN LAKES RD							Town of SOLON SPRINGS				11350				
City SOLON SPRINGS					State WI		Zip Code 54873				Street Address or Road Name and Number S TWIN LAKES RD				
County Douglas		Co. Permit #		Notification # 10265071601		Completed 05-13-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) WAYNE HOLLY WELL DRILLING LLC				Lic. # 9031		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.35473 °N -91.73712 °W				Method Code SCR002			
Address 71385 HOOVER LINE RD IRON RIVER WI 54847				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 27 45 N 11 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.9											
3. Well serves 1 # of SHOP Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		61		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				K N S M K-BLACK N-FINE S-SAND M-SILTY O A P G O-ORANGE A-COARSE P-HARDPAN G-W/GRAVEL/STONES T N S T-TAN/BROWN N-FINE S-SAND T A S T-TAN/BROWN A-COARSE S-SAND		Surface		25	
												25		45	
												45		55	
												55		61	
6. Casing, Liner, Screen												9. Static Water Level 27 ft. below ground surface		11. Well Is 20 in. above grade	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10. Pump Test Pumping level 35 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Test Pump		Developed ? Yes Disinfected ? Yes Capped ? Yes			
5		SDR 17 PVC, NORTH AMERICAN SPECIALTY, ASTM F480 - GLUED				Surface		57							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		10 SLOT STAINLESS STEEL FLATBOTTOM				57		61							
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? No			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No					
GRANULAR BENTONITE				Surface		50		5 S							
13. Constructor / Supervisory Driller												Lic #		Date Signed	
DH												8983		05-14-2026	
Drill Rig Operator												Lic or Reg #		Date Signed	
LS												9410		05-14-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 05-14-2026

Updated On: 07-09-2026

Review Status: APPROVED