Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN436

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SEVERIN, ERIC	Phone #: (218)590-7140
Mailing Address: 11350 S TWIN LAKES RD	
City: SOLON SPRINGS	State: WI — Zip Code: 54873
County: Douglas	Co. Permit #:
Notification #: 10265071601	Completed: 05-13-2026
Well Constructor (Business Name): WAYNE HOLLY WELL DRILLING LLC	Lic. #: 9031
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 71385 HOOVER LINE RD, IRON RIVER WI 54847	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.9	

1. Well Location

Town of SOLON SPRINGS	Fire # (if avail.): 11350
Street Address or Road Name and Number: S TWIN LAKES RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.35473 °N -91.73712 °W	Method Code: SCR002

SW	NW	Section	Township	Range
or Govt Lot #		27	45 N	11 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of SHOP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	61

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	N	S	M	K-BLACK N-FINE S-SAND M-SILTY	Surface	25
O	A	P	G	O-ORANGE A-COARSE P-HARDPAN G-W/GRAVEL/STONES	25	45
T	N	S		T-TAN/BROWN N-FINE S-SAND	45	55
T	A	S		T-TAN/BROWN A-COARSE S-SAND	55	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR 17 PVC, NORTH AMERICAN SPECIALTY, ASTM F480 - GLUED	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT STAINLESS STEEL FLATBOTTOM	57	61

9. Static Water Level
27 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	50	5 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH	8983	05-14-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LS	9410	05-14-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 05-14-2026 Updated On: 07-09-2026 Review Status: APPROVED