

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACN515		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner CIKANEK, MILAN						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 2321 SHADOWVIEW CIRCLE						Town of MINOCQUA						8993					
City PLOVER						State WI		Zip Code 54467				Street Address or Road Name and Number ARNOLD STOCK LN					
County Oneida		Co. Permit #		Notification # 10248726602		Completed 05-06-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) D&M WATERWORKS LLC				Lic. # 9148		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8912 °N -89.8896 °W				Method Code GPS008					
Address DBA/RICHARDSON WELL DRLG 10632 STATE HWY 70 WEST MINOCQUA WI 54548				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 5 39 N 5 E		2. Well Type Replacement				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 1.4		Reason for replaced or reconstructed well ? NO WATER IN OLD POINT											
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled											
Private, potable Drillhole				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		28		Yes Rotary - Mud Circulation		No		Y		Y-SAND & GRAVEL		Surface		28	
						No Rotary - Air		No									
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				12 in. above grade			
5		SDR21 PVC 200 PSI, ASTM D2241-F480, CRESLINE, GLUED				Surface		25		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 15 ft. below surface				Disinfected ? Yes			
4		ALLOY SS 10 SLOT				25		28		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes			
										Pumping Method ? Test Pump							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes					
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes			
BENTONITE GROUT, 20% SOLIDS, 9.8 LBS				Surface		22		2 S									
#40 GRAVEL PACK, RED FLINT				22		28		8 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
TF												8520		05-06-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
CM												8443		05-06-2026			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NEW SEPTIC GOING IN. NOT IN AT THE TIME OF DRILLING

Created On: 05-18-2026

Updated On: 06-01-2026

Review Status: APPROVED