Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACN515

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CIKANEK, MILAN	Phone #
Mailing Address: 2321 SHADOWVIEW CIRCLE	
City: PLOVER	State: WI — Zip Code: 54467

County	Co. Permit #	Notification #	Completed
Oneida		10248726602	05-06-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
D&M WATERWORKS LLC	9148	

Address: DBA/RICHARDSON WELL DRLG 10632
STATE HWY 70 WEST
MINOCQUA WI 54548

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.4

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of MINOCQUA

Fire # (if avail.): 8993

Street Address or Road Name and Number: ARNOLD STOCK LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.8912 °N	-89.8896 °W			GPS008

SW	SE	Section	Township	Range
or Govt Lot #		5	39 N	5 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

NO WATER IN OLD POINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	28

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	28

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR21 PVC 200 PSI, ASTM D2241-F480, CRESLINE, GLUED	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	ALLOY SS 10 SLOT	25	28

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT, 20% SOLIDS, 9.8 LBS	Surface	22	2 S
#40 GRAVEL PACK, RED FLINT	22	28	8 S

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	8520	05-06-2026
Drill Rig Operator	Lic or Reg #	Date Signed
CM	8443	05-06-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NEW SEPTIC GOING IN. NOT IN AT THE TIME OF DRILLING

Created On: 05-18-2026 Updated On: 06-01-2026 Review Status: APPROVED