

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AJ710		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DEABOLD JUST						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address HC 32 BOX 160						Town of ROME													
City LAWTON						State OK		Zip Code 73501				Street Address or Road Name and Number 1572 APACHE AVE							
County Adams		Co. Permit #		Notification #		Completed 11-29-1988		Subdivision Name				Lot #	Block #						
Well Constructor (Business Name) FOSTER RAY E				Lic. # 164	Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 44.1993 °N -89.87288 °W				Method Code GCD005							
Address RT 1 2540 HWY 13 BOX ADAMS WI 53910				Well Plan Approval # Approval Date (mm-dd-yyyy)			SE	SW	Section 14	Township 20 N	Range 5 E								
							or Govt Lot #												
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT PLUGGED													
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)					
6	Surface	6	Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				T S BROWN SAND Surface 31 T C BROWN CLAY 31 42 W S BROWN FINE SAND 42 55 A S LT BROWN COARSE SAND 55 61.5												
2	6	61.5																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	44 ft. below ground surface				16 in. above grade								
2	SAWHILL TYPE #II ASTM-A-589-#3.75				Surface	58.5	10. Pump Test				Developed ? Yes								
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)	Pumping level 44 ft. below surface				Disinfected ? Yes								
1.25	JOHNSON SCREEN				58.5	61.5	Pumping at 7 GP for 1 Hrs.				Capped ? Yes								
							Pumping Method ?												
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method														Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement															
CLAY		Surface	6																
														13. Constructor / Supervisory Driller				Lic #	Date Signed
														REF		01-05-1989			
														Drill Rig Operator	Lic or Reg #	Date Signed			
														REF		01-05-1989			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		32	Privy		750
Building Overhang		4	Sewer - Building Sanitary		35
			Septic or Holding, or POWTS Tank		38

Comment:

Created On: 10-19-1989

Updated On: 07-12-2021

Review Status: