Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AJ710

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DEABOLD JUST	Phone #
Mailing Address: HC 32 BOX 160	
City: LAWTON	State: OK — Zip Code: 73501
County: Adams	Co. Permit #	Notification #	Completed: 11-29-1988

Well Constructor (Business Name): FOSTER RAY E	Lic. #: 164	Facility ID # (Public Wells)	
Address: RT 1 2540 HWY 13 BOX ADAMS WI 53910		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

1. Well Location

Town of ROME

Fire # (if avail.)

Street Address or Road Name and Number: 1572 APACHE AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.1993 °N	-89.87288 °W			GCD005
SE SW or Govt Lot #	Section: 14	Township: 20 N	Range: 5 E	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: POINT PLUGGED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	61.5

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN SAND	Surface	31
T		C		BROWN CLAY	31	42
	W	S		BROWN FINE SAND	42	55
	A	S		LT BROWN COARSE SAND	55	61.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL TYPE #II ASTM-A-589-#3.75	Surface	58.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON SCREEN	58.5	61.5

9. Static Water Level

44 ft. below ground surface

10. Pump Test

Pumping level 44 ft. below surface

Pumping at 7 GP for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY	Surface	6	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
REF		01-05-1989
Drill Rig Operator	Lic or Reg #	Date Signed
REF		01-05-1989

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		32
Building Overhang		4
Privy		750
Sewer - Building Sanitary		35
Septic or Holding, or POWTS Tank		38

Comment:

Created On: 10-19-1989 Updated On: 07-12-2021 Review Status: