

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AK733		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner RAY UCHYTIL Phone # (715)237-2501						1. Well Location				Fire # (if avail.)				
Mailing Address RT 1 BOX 100A						Town of OAK GROVE				Street Address or Road Name and Number				
City NEW AUBURN				State WI		Zip Code 54757								
County Barron		Co. Permit #		Notification #		Completed 05-20-1989		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) KRAMER WELL DRILLING INC				Lic. # 45		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Address N3055 COUNTY W WEYERHAEUSER WI 54895				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 19 36 N 11 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? WAS GETTING WATER FROM NE						
Approval Date (mm-dd-yyyy)				Specific Capacity 5		Construction Type Drilled								
Hicap Permanent Well #				Common Well #		Hicap Well ? No Hicap Property ? No Hicap Potable ?		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) 6		From (ft.) Surface		To (ft.) 60		Upper Enlarged Drillhole		Lower Open Bedrock						
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
I		TOP SOIL				Surface		1						
Q S G		SAND @ GRAVEL CAVING BR				1		22						
V Y C		SAND GRAVEL @ CLAY NON CAVING BR				22		45						
Q S G		CAVING SAND @ GRAVEL BR				45		60						
6. Casing, Liner, Screen														
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly P.E. LTV STEEL 19LB/FT ASTM A-53				From (ft.) Surface		To (ft.) 57						
Dia. (in.) 4		Screen type, material & slot size STAINLESS STEEL WIRE WORD				From (ft.) 56		To (ft.) 60						
7. Grout or Other Sealing Material Method														
9. Static Water Level 45 ft. below ground surface														
10. Pump Test Pumping level 48 ft. below surface Pumping at 15 GP for 1 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
GJ										05-23-1989				
Drill Rig Operator								Lic or Reg #		Date Signed				
GJ										05-23-1989				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		40
Building Overhang		10	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 10-19-1989

Updated On: 10-19-1989

Review Status: