Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AK734

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARVIN ANDERSON	Phone #: (715)357-3114
Mailing Address: RT 1 BOX 82	
City: ALMENA	State: WI Zip Code: 54805
County: Barron	Co. Permit #:
Notification #:	Completed: 05-18-1989
Well Constructor (Business Name): KRAMER WELL DRILLINGINC	Lic. #: 45
Facility ID # (Public Wells):	
Address: N3055 COUNTY W WEYERHAEUSER WI 54895	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.5	

1. Well Location

Fire # (if avail.):

Town of ARLAND

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SE or Govt Lot #: | Section: 15 | Township: 33 N | Range: 13 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	137

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I			TOP SOIL	Surface	1
V	Y	C		SAND GRAVEL @ CLAY BR NON CAVING	1	31
V	S	C		SAND @ CLAY BR NON CAVING	31	55
S	N			SOFT SANDSTONE	55	113
H	N			HARD SANDSTONE	113	137

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. LTV STEEL 19 LBS/FT ASTM A/53	Surface	113
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

100 ft. below ground surface

10. Pump Test

Pumping level 104 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method SHOVELED IN

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GJ		05-23-1989
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
GJ		05-23-1989

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		22

Comment:

Created On: 10-19-1989 Updated On: 10-19-1989 Review Status: