

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AK734		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MARVIN ANDERSON						Phone # (715)357-3114		1. Well Location				Fire # (if avail.)					
Mailing Address RT 1 BOX 82						Town of ARLAND						Street Address or Road Name and Number					
City ALMENA				State WI		Zip Code 54805											
County Barron		Co. Permit #		Notification #		Completed 05-18-1989		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) KRAMER WELL DRILLING INC				Lic. # 45		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address N3055 COUNTY W WEYERHAEUSER WI 54895				Well Plan Approval #				°N		°W		Range		13 W			
				Approval Date (mm-dd-yyyy)				SW SE		Section 15						Township 33 N	
Hicap Permanent Well #				Common Well #		Specific Capacity 2.5				2. Well Type New Well				Reason for replaced or reconstructed well ? NEW HOME			
3. Well serves 1 # of				Hicap Well ? No				Construction Type Drilled									
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?				of previous unique well # constructed in									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method								8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		I C		TOP SOIL		Surface		1			
6		20		137						V Y C		SAND GRAVEL @ CLAY BR NON CAVING		1		31	
										V S C		SAND @ CLAY BR NON CAVING		31		55	
										S N		SOFT SANDSTONE		55		113	
										H N		HARD SANDSTONE		113		137	
6. Casing, Liner, Screen								9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		100 ft. below ground surface				14 in. above grade			
6		P.E. LTV STEEL 19 LBS/FT ASTM A/53				Surface		113		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 104 ft. below surface				Disinfected ? Yes			
										Pumping at 10 GP for 2 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material								12. Notified Owner of need to fill & seal ?									
Method SHOVELED IN								Filled & Sealed Well(s) as needed?									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
DRILL CUTTINGS		Surface		20													
								13. Constructor / Supervisory Driller				Lic #		Date Signed			
								GJ						05-23-1989			
								Drill Rig Operator				Lic or Reg #		Date Signed			
								GJ						05-23-1989			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		22

Comment:

Created On: 10-19-1989

Updated On: 10-19-1989

Review Status: