Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AK966

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROD COWAN	Phone #: (715)878-4272
Mailing Address: RT 1 BOX 128A	
City: ELEVA	State: WI Zip Code: 54738
County: Sawyer	Co. Permit #:
Notification #:	Completed: 05-26-1989
Well Constructor (Business Name): KRAMER WELL DRILLINGINC	Lic. #: 45
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: N3055 COUNTY W WEYERHAEUSER WI 54895	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3	

1. Well Location

Town of NW CENTRAL WINTER

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW NE or Govt Lot #: | Section: 2 | Township: 39 N | Range: 5 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

CABIN ON LAKE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	1
	Q	S	G	CAVING BR SAND @ GRAVEL	1	30
	Q	S	G	CAVING BL. SAND @ GRAVEL IRONY	30	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. NKK STEEL 19LBS/FT ASTM A-53	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL WIRE WOUND	46	50

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 15 GP for 7 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GJ		05-31-1989
Drill Rig Operator	Lic or Reg #	Date Signed
GJ		05-31-1989

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Overhang		10
Shoreline/Pool		204

Type	Qualifier	Distance
Privy		60
Sewer - Building Sanitary		42
Septic or Holding, or POWTS Tank		51

Comment:

Created On: 10-19-1989 Updated On: 10-19-1989 Review Status: