Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AR735

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BERGESEN, SID	Phone #: (414)728-2824
Mailing Address: 2334 S SHORE DR	
City: DELAVAN	State: WI — Zip Code: 53115
County: Walworth	Co. Permit #: — Notification #: — Completed: 07-19-1994
Well Constructor (Business Name): JAMES L DIETZMAN	Lic. #: 297 — Facility ID # (Public Wells):
Address: 1631 MOUND RD, DELAVAN WI 53115	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location
Town of DELAVAN
Fire # (if avail.):
Street Address or Road Name and Number:
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:
SE NW or Govt Lot #: — Section: 27 — Township: 2 N — Range: 16 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	65

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK STEEL 18.97# P@E SAWHILL ASTMA53	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL #15	62	65

9. Static Water Level
17 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MOUNDED BENTONITE CASING SEAL	Surface	0	2 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JPD		07-30-1994
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		38	Shoreline/Pool		400
Collector Sewer - San or Storm		200	Sewer - Building Sanitary		60

Comment:

Created On: 12-12-1994 Updated On: 12-12-1994 Review Status: