Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AR736

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CZARNECKI, ART			Phone #: (414)379-4799
Mailing Address: PO BOX 592			
City: ELKHORN	State: WI	Zip Code: 53121	
County: Walworth	Co. Permit #:	Notification #:	Completed: 08-16-1994

1. Well Location

Town of SUGAR CREEK

Fire # (if avail.):

Street Address or Road Name and Number: W5130 MEMORIAL DR

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): JAMES L DIETZMAN	Lic. #: 297	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 42.7442 °N -88.5554 °W
Method Code: GCD013			
Well Plan Approval #:			SE SW or Govt Lot #:	Section: 1	Township: 3 N	Range: 16 E
Address: 1631 MOUND RD DELAVAN WI 53115			Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3	

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	119

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	28
		C		CLAY	28	70
		C	S	SANDY CLAY	70	110
		Y		SAND @ GRAVEL	110	119

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
61	BLK STEEL SAWHILL P@E ASTM A53 18.98#	Surface	116
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
51	STAINLESS STEEL #12	116	119

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 10 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CASING SEAL	Surface	0	1 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JD		08-22-1994
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		15
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 11-03-1994 Updated On: 09-12-2019 Review Status: