

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AR737		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner HANSEN, ROBERT					Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 706 E GENEVA ST					Town of DARIEN					8005				
City DELAVAN				State WI		Zip Code 53115								
County Walworth		Co. Permit #		Notification #		Completed 09-12-1994		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) JAMES L DIETZMAN				Lic. # 297		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code		
Address 1631 MOUND RD DELAVAN WI 53115				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		NE NW Section Township Range or Govt Lot # 14 2 N 15 E		2. Well Type Replacement		
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ?								
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Other						
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		155		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)				
I		TOPSOIL						Surface		1				
S		SAND						1		36				
X		CLAY @ SAND						36		115				
L		LIMESTONE						115		155				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		BLK STEEL SUMITO ASTM A53 P@E 18.97#				Surface		115						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material										9. Static Water Level				
Method										60 ft. below ground surface				
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is						
CASING SEAL		Surface		0		1 S		14 in. above grade						
10. Pump Test										Developed ? Yes				
Pumping level 80 ft. below surface										Disinfected ? Yes				
Pumping at 10 GP M for 10 Hrs.										Capped ? Yes				
Pumping Method ?										12. Notified Owner of need to fill & seal ?				
Filled & Sealed Well(s) as needed?										Yes				
13. Constructor / Supervisory Driller										Lic #		Date Signed		
JD										09-14-1994				
Drill Rig Operator										Lic or Reg #		Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		10
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 12-05-1994

Updated On: 07-11-2023

Review Status: