

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AS332		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ROSALIE MURPHY						Phone # (414)834-3269		1. Well Location				Fire # (if avail.)			
Mailing Address 5313 STILES RD						Town of STILES						Street Address or Road Name and Number			
City LENA				State WI		Zip Code 54139									
County Oconto		Co. Permit #		Notification #		Completed 06-02-1992		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) YOUNG, BERNARD				Lic. # 696		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code				
Address 10358 HWY 22E GILLETT WI 54124				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		Section 34		Township 28 N		Range 20 E	
								NE NW							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6		2. Well Type New Well							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		of previous unique well # constructed in							
								Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ?		NEW HOME									
Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 83		Upper Enlarged Drillhole				Lower Open Bedrock					
						Rotary - Mud Circulation									
						Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Yes Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
S		SAND						Surface		43					
C S		SANDY CLAY						43		71					
C		CLAY						71		80					
G		GRAVEL						80		83					
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification NEWPORT STEEL 1780 PSI ASTM A-53 WELDED 18.97				From (ft.) Surface		To (ft.) 83		9. Static Water Level 38 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material Method										10. Pump Test Pumping level 65 ft. below surface Pumping at 15 GP for 10 Hrs. Pumping Method ?					
										11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
										12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller						Lic #		Date Signed							
BY								06-02-1992							
Drill Rig Operator						Lic or Reg #		Date Signed							
BY															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		21
			Septic or Holding, or POWTS Tank		32

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: