

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AT491		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RON ASFOOD						Phone # (608)784-2778		1. Well Location				Fire # (if avail.)							
Mailing Address 1619 NAKOMIS AVE						Town of FARNINGTON													
City LA CROSSE						State WI		Zip Code 54602											
County La Crosse		Co. Permit #		Notification #		Completed 10-10-1989		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) STAUFFER RICHARD H				Lic. # 231		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address N5254 HWY 53 ONALASKA WI 54650				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 3 18 N 5 W													
Hicap Permanent Well #				Common Well #		Specific Capacity 1		2. Well Type New Well				of previous unique well # constructed in							
3. Well serves 1 # of				Hicap Well ? No		Private, potable		Hicap Property ? No		Reason for replaced or reconstructed well ?		WATER SUPPLY							
Heat Exchange ____ # of drillholes				Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		46		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				S		SAND		Surface		46			
6		46		77						N		SANDSTONE		46		100			
5		77		100															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				14 in. above grade					
6.625		NEW BLACK P.E. STEEL WELD 18.97# .280 WALL ASTM A53-A TAIWAN NEW BLACK STEEL P.E. STEEL WELD 14.62# .258 WALL				Surface		46		10. Pump Test				Developed ? Yes					
5.562		ASTM A53-A				35		77		Pumping level 45 ft. below surface Pumping at 10 GP for 3 Hrs.				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?				Capped ? Yes					
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?				Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
DRILL MUD				Surface		46													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RS						09-27-1989	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												RO						01-05-1989	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		72
Building Overhang		57	Septic or Holding, or POWTS Tank		87

Comment: DRILLER REPORTS 5.6" LINER INSTALLED BECAUSE OF CAVING SAND**Created On:** 02-26-1991**Updated On:** 10-24-2002**Review Status:**