Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AU050

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEORGE BATORSKI			Phone #: (414)862-6527
Mailing Address: 11805 218TH ST			
City: BRISTOL	State: WI	Zip Code: 53104	
County: Kenosha	Co. Permit #:	Notification #:	Completed: 09-05-1990

Well Constructor (Business Name): HUBERT R JOHNSON	Lic. #: 626	Facility ID # (Public Wells):
Address: RT 2 BOX 110 GENOA CITY WI 53128-9509		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.4

1. Well Location

Village of BRISTOL

Fire # (if avail.):

Street Address or Road Name and Number: 11805 218TH ST

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #:	Section: 31	Township: 1 N	Range: 21 E

2. Well Type Replacement

of previous unique well #: constructed in: 50

Reason for replaced or reconstructed well ?: INABILITY TO INSTALL SUB

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	SANDY BRN CLAY	Surface	42
G		C		GRAY CLAY	42	85
	J	G		BRN GRAVEL	85	96
G		C		GRAY CLAY	96	127
		Y		SAND GRAVEL	127	136

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5.556	A53 T@C 15#PER FT VALLEY STEEL	Surface	133
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	15 SLOT SS WIRE WRAP	133	136

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL MUD CLAY	Surface	20	

9. Static Water Level

80 ft. below ground surface

10. Pump Test

Pumping level 85 ft. below surface

Pumping at 12 GP for 24 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HJ		09-06-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Nonconforming Pit or Alcove		10
			Sewer - Building Sanitary		25

Comment:

Created On: 03-07-1991 Updated On: 03-07-1991 Review Status: