

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AU050		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GEORGE BATORSKI						Phone # (414)862-6527		1. Well Location				Fire # (if avail.)	
Mailing Address 11805 218TH ST						Village of BRISTOL							
City BRISTOL						State WI		Zip Code 53104					
County Kenosha		Co. Permit #		Notification #		Completed 09-05-1990		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) HUBERT R JOHNSON				Lic. # 626		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address RT 2 BOX 110 GENOA CITY WI 53128-9509				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NW Section Township Range or Govt Lot # 31 1 N 21 E					
Hicap Permanent Well #		Common Well #		Specific Capacity 2.4		2. Well Type Replacement of previous unique well # constructed in 50							
						Reason for replaced or reconstructed well ? INABILITY TO INSTALL SUB							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
10		Surface		20									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
G C S		SANDY BRN CLAY		Surface		42							
G C		GRAY CLAY		42		85							
J G		BRN GRAVEL		85		96							
G C		GRAY CLAY		96		127							
Y		SAND GRAVEL		127		136							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
5.556		A53 T@C 15#PER FT VALLEY STEEL				Surface		133					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		15 SLOT SS WIRE WRAP				133		136					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
DRILL MUD CLAY				Surface		20							
9. Static Water Level													
80 ft. below ground surface													
10. Pump Test													
Pumping level 85 ft. below surface													
Pumping at 12 GP for 24 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
HJ				09-06-1990									
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Nonconforming Pit or Alcove		10
			Sewer - Building Sanitary		25

Comment:

Created On: 03-07-1991

Updated On: 03-07-1991

Review Status: