

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AV553		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner JIM VAN HARDAL						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 1827 CTY J						Town of HOGRA						Street Address or Road Name and Number											
City LT SUAMICO						State WI		Zip Code 54141				FLORIST DR											
County Brown		Co. Permit #		Notification #		Completed 12-01-1988		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) VAN DE YACHT BILL				Lic. # 37		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address 4151 LEDGECREST RD DE PERE WI 54115				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE °N		Section 2		Township 23 N		Range 19 E									
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6				or Govt Lot #				Range									
3. Well serves 1 # of						Hicap Well ? No				2. Well Type New Well													
Private, potable						Hicap Property ? No				of previous unique well # constructed in													
Heat Exchange ___ # of drillholes						Hicap Potable ?				Reason for replaced or reconstructed well ?													
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled																	
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)		
9			Surface			105			Yes Rotary - Mud Circulation			Yes Rotary - Air			C CLAYU		Surface		25				
6			105			170			Yes Rotary - Air & Foam			Drill-Through Casing Hammer			G GRAVEL		25		30				
6			105			170			Reverse Rotary			Cable-tool Bit ___ in. dia...			C CLAY		30		105				
6			105			170			Dual Rotary			Temp. Outer Casing ___ in. dia			L LIME		105		150				
6			105			170			Removed? ___ depth ft. (If NO explain on back side)			N SANDSTONE			150		170						
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)		To (ft.)		100 ft. below ground surface				12 in. above grade						
6			NEW 61. STLPL. END WELDED A53 GR B. 18.97 280 U.S.						Surface		106		10. Pump Test				Developed ? Yes						
Dia. (in.)			Screen type, material & slot size						From (ft.)		To (ft.)		Pumping level 150 ft. below surface				Disinfected ? Yes						
6			106						106		106		Pumping at 30 GP for 2 Hrs.				Capped ? Yes						
6			106						106		106		Pumping Method ?				Filled & Sealed Well(s) as needed? Yes						
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?											
Method												Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material						From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed	
DRILL SLURRY						Surface		105		BV						12-01-1988		12-01-1988					
DRILL SLURRY						Surface		105		Drill Rig Operator						Lic or Reg #		Date Signed					
DRILL SLURRY						Surface		105		BV						12-01-1988		12-01-1988					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		97	Building Overhang		11
			Septic or Holding, or POWTS Tank		78

Comment:

Created On: 11-16-1989

Updated On: 11-16-1989

Review Status: