

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				BF511		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner MADISON, CITY OF						Phone # (608)266-4656		1. Well Location				Fire # (if avail.)											
Mailing Address 523 E MAIN ST						City of MADISON																	
City MADISON				State WI		Zip Code 53703																	
County Dane		Co. Permit #		Notification #		Completed 01-01-1956		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) EGERER-GALLOWAY				Lic. # 21		Facility ID # (Public Wells) 113022470				Method Code													
Address				Well Plan Approval # 560052		or Govt Lot #		Section 4		Township 7 N		Range 10 E											
				Approval Date (mm-dd-yyyy) 03-07-1956		2. Well Type New Well																	
Hicap Permanent Well # 77131		Common Well # 011		Specific Capacity 22.4		Reason for replaced or reconstructed well ?																	
3. Well serves # of Municipal/Community				Hicap Well ? No		Construction Type Drilled																	
Heat Exchange # of drillholes				Hicap Property ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
30		Surface		33.33		No Rotary - Mud Circulation				No				T L		TILL				Surface		15	
28		33.33		110.67		No Rotary - Air				No				G S		GRAVEL				15		18	
22		110.67		752.67		No Rotary - Air & Foam				No				N L		SANDSTONE FRANCO				18		120	
						No Drill-Through Casing Hammer								N		SANDSTONE GALESV				120		200	
						No Reverse Rotary								N		SANDSTONE EC				200		365	
						No Cable-tool Bit ____in. dia...				No				N		SANDSTONE MT SIMON				365		723	
						No Dual Rotary				No				P Q		RHYOLITE PC				723		752	
						No Temp. Outer Casing ____in. dia																	
						No Removed? ____depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				0 in. ____ grade									
30						Surface		33.33		10. Pump Test Pumping level 116 ft. below surface Pumping at 2155 GP M for 6.3 Hrs. Pumping Method ?				Developed ? No Disinfected ? No Capped ? No									
24						33.33		110.67															
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No									
Method														Filled & Sealed Well(s) as needed? No									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement																	
CEMENT		Surface		110.67																			
13. Constructor / Supervisory Driller						Lic #		Date Signed															
Drill Rig Operator						Lic or Reg #		Date Signed															

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-19-1998

Updated On: 05-22-2019

Review Status: