

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				BF519		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																																																																																							
Property Owner MADISON, CITY OF						Phone # (608)266-4656		1. Well Location				Fire # (if avail.)																																																																																					
Mailing Address 523 E MAIN ST						City of MADISON																																																																																											
City MADISON				State WI		Zip Code 53703																																																																																											
County Dane		Co. Permit #		Notification #		Completed 04-01-1970		Subdivision Name				Lot #		Block #																																																																																			
Well Constructor (Business Name) LAYNE CHRISTENSEN COMPANY				Lic. # 582		Facility ID # (Public Wells) 113022470				Method Code GPS008																																																																																							
Address W229 N5005 DUPLAINVI PEWAUKEE WI 53072				Well Plan Approval # 69-0916		Approval Date (mm-dd-yyyy) 12-10-1969		or Govt Lot #		Section 16		Township 7 N		Range 9 E																																																																																			
Hicap Permanent Well # 77139				Common Well # 019		Specific Capacity 14.2				2. Well Type New Well																																																																																							
3. Well serves # of Municipal/Community				Hicap Well ? No		Hicap Property ? No				of previous unique well # constructed in																																																																																							
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled																																																																																							
4. Potential Contamination Sources - ON REVERSE SIDE																																																																																																	
5. Drillhole Dimensions and Construction Method																																																																																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Dia. (in.)</th> <th>From (ft.)</th> <th>To (ft.)</th> <th>Upper Enlarged Drillhole</th> <th>Lower Open Bedrock</th> </tr> </thead> <tbody> <tr> <td>42</td> <td>Surface</td> <td>18</td> <td>No Rotary - Mud Circulation</td> <td>No</td> </tr> <tr> <td>35</td> <td>260</td> <td>18</td> <td>No Rotary - Air</td> <td>No</td> </tr> <tr> <td>26</td> <td>260</td> <td>711.5</td> <td>No Rotary - Air & Foam</td> <td>No</td> </tr> <tr> <td>24</td> <td>711.5</td> <td>714</td> <td>No Drill-Through Casing Hammer</td> <td></td> </tr> <tr> <td>17</td> <td>714</td> <td>718</td> <td>No Reverse Rotary</td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td>No Cable-tool Bit ___ in. dia...</td> <td>No</td> </tr> <tr> <td></td> <td></td> <td></td> <td>No Dual Rotary</td> <td>No</td> </tr> <tr> <td></td> <td></td> <td></td> <td>No Temp. Outer Casing ___ in. dia</td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td>No Removed? ___ depth ft. (If NO explain on back side)</td> <td></td> </tr> </tbody> </table>														Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole	Lower Open Bedrock	42	Surface	18	No Rotary - Mud Circulation	No	35	260	18	No Rotary - Air	No	26	260	711.5	No Rotary - Air & Foam	No	24	711.5	714	No Drill-Through Casing Hammer		17	714	718	No Reverse Rotary					No Cable-tool Bit ___ in. dia...	No				No Dual Rotary	No				No Temp. Outer Casing ___ in. dia					No Removed? ___ depth ft. (If NO explain on back side)																																			
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole	Lower Open Bedrock																																																																																													
42	Surface	18	No Rotary - Mud Circulation	No																																																																																													
35	260	18	No Rotary - Air	No																																																																																													
26	260	711.5	No Rotary - Air & Foam	No																																																																																													
24	711.5	714	No Drill-Through Casing Hammer																																																																																														
17	714	718	No Reverse Rotary																																																																																														
			No Cable-tool Bit ___ in. dia...	No																																																																																													
			No Dual Rotary	No																																																																																													
			No Temp. Outer Casing ___ in. dia																																																																																														
			No Removed? ___ depth ft. (If NO explain on back side)																																																																																														
8. Geology																																																																																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3">Geology Codes</th> <th>Type, Caving/Noncaving, Color, Hardness, etc...</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> </thead> <tbody> <tr> <td>O</td> <td></td> <td>Y</td> <td>CLAY @ SAND</td> <td>Surface</td> <td>15</td> </tr> <tr> <td></td> <td>N</td> <td>N</td> <td>SANDSTONE-TUNNEL CITY</td> <td>15</td> <td>110</td> </tr> <tr> <td></td> <td></td> <td>N</td> <td>SANDSTONE-WONEWOC</td> <td>110</td> <td>220</td> </tr> <tr> <td></td> <td></td> <td>H N</td> <td>SHALE @ SS-EAU CLAIRE</td> <td>220</td> <td>255</td> </tr> <tr> <td></td> <td>N</td> <td>L S</td> <td>DOLOMITE-MT SIMON</td> <td>255</td> <td>258</td> </tr> <tr> <td></td> <td>M</td> <td>N</td> <td>SANDSTONE-MT SIMON</td> <td>258</td> <td>300</td> </tr> <tr> <td></td> <td>N</td> <td>L H</td> <td>DOLOMITE-MT SIMON</td> <td>300</td> <td>305</td> </tr> <tr> <td></td> <td></td> <td>N</td> <td>SANDSTONE-MT SIMON</td> <td>305</td> <td>365</td> </tr> <tr> <td></td> <td>N</td> <td>L</td> <td>LIMESTONE-MT SIMON</td> <td>365</td> <td>370</td> </tr> <tr> <td>P</td> <td></td> <td>N</td> <td>SANDSTONE-MT SIMON</td> <td>370</td> <td>640</td> </tr> <tr> <td>O</td> <td></td> <td>A M</td> <td>CONGLOMERATE-MT SIMON</td> <td>640</td> <td>645</td> </tr> <tr> <td></td> <td></td> <td>N</td> <td>SANDSTONE-MT SIMON</td> <td>645</td> <td>710</td> </tr> <tr> <td>T</td> <td></td> <td>H</td> <td>SHALE-PRECAMBRIAN</td> <td>710</td> <td>718</td> </tr> </tbody> </table>														Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	O		Y	CLAY @ SAND	Surface	15		N	N	SANDSTONE-TUNNEL CITY	15	110			N	SANDSTONE-WONEWOC	110	220			H N	SHALE @ SS-EAU CLAIRE	220	255		N	L S	DOLOMITE-MT SIMON	255	258		M	N	SANDSTONE-MT SIMON	258	300		N	L H	DOLOMITE-MT SIMON	300	305			N	SANDSTONE-MT SIMON	305	365		N	L	LIMESTONE-MT SIMON	365	370	P		N	SANDSTONE-MT SIMON	370	640	O		A M	CONGLOMERATE-MT SIMON	640	645			N	SANDSTONE-MT SIMON	645	710	T		H	SHALE-PRECAMBRIAN	710	718
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																																																																																												
O		Y	CLAY @ SAND	Surface	15																																																																																												
	N	N	SANDSTONE-TUNNEL CITY	15	110																																																																																												
		N	SANDSTONE-WONEWOC	110	220																																																																																												
		H N	SHALE @ SS-EAU CLAIRE	220	255																																																																																												
	N	L S	DOLOMITE-MT SIMON	255	258																																																																																												
	M	N	SANDSTONE-MT SIMON	258	300																																																																																												
	N	L H	DOLOMITE-MT SIMON	300	305																																																																																												
		N	SANDSTONE-MT SIMON	305	365																																																																																												
	N	L	LIMESTONE-MT SIMON	365	370																																																																																												
P		N	SANDSTONE-MT SIMON	370	640																																																																																												
O		A M	CONGLOMERATE-MT SIMON	640	645																																																																																												
		N	SANDSTONE-MT SIMON	645	710																																																																																												
T		H	SHALE-PRECAMBRIAN	710	718																																																																																												
6. Casing, Liner, Screen																																																																																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Dia. (in.)</th> <th>Material, Weight, Specification Manufacturer & Method of Assembly</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> </thead> <tbody> <tr> <td>42</td> <td>NEW STEEL WELDED 0 375 WALL</td> <td>Surface</td> <td>18</td> </tr> <tr> <td>30</td> <td>ASTM A53 GR B 0 500 WALL WELDED-2.5' ABOVE SURFACE</td> <td>0</td> <td>260</td> </tr> </tbody> </table>														Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)	42	NEW STEEL WELDED 0 375 WALL	Surface	18	30	ASTM A53 GR B 0 500 WALL WELDED-2.5' ABOVE SURFACE	0	260																																																																								
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)																																																																																														
42	NEW STEEL WELDED 0 375 WALL	Surface	18																																																																																														
30	ASTM A53 GR B 0 500 WALL WELDED-2.5' ABOVE SURFACE	0	260																																																																																														
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Dia. (in.)</th> <th>Screen type, material & slot size</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>														Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																																																																																
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																																																																																														
7. Grout or Other Sealing Material																																																																																																	
Method																																																																																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Kind of Sealing Material</th> <th>From (ft.)</th> <th>To (ft.)</th> <th># Sacks Cement</th> </tr> </thead> <tbody> <tr> <td>NEAT CEMENT</td> <td>Surface</td> <td>260</td> <td></td> </tr> </tbody> </table>														Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement	NEAT CEMENT	Surface	260																																																																													
Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement																																																																																														
NEAT CEMENT	Surface	260																																																																																															

9. Static Water Level

62.8 ft. below ground surface

10. Pump Test

Pumping level 221 ft. below surface

Pumping at 2250 GP M for 10 Hrs.

Pumping Method ?

11. Well Is

0 in. _____ grade

Developed ? No

Disinfected ? No

Capped ? No

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: ADD'L DRILLHOLE OF 35" FROM 18' TO 260'

Created On: 01-05-1999

Updated On: 05-22-2019

Review Status: