Well Construction Report
WISCONSIN UNIQUE WELL NUMBER BG326

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WAUSAU, CITY OF			Phone #: (715)843-1430
Mailing Address: 407 GRANT ST			
City: WAUSAU	State: WI	Zip Code: 54401	
County: Marathon	Co. Permit #:	Notification #:	Completed: 01-01-1961

1. Well Location

City of WAUSAU

Fire # (if avail.):

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): MILLER WELL & PUMP	Lic. #: 208	Facility ID # (Public Wells): 737010230	Method Code:
Address:		Well Plan Approval #: 61-0005	
		Approval Date (mm-dd-yyyy): 01-06-1961	
Hicap Permanent Well #: 81952	Common Well #: 003	Specific Capacity: 40.7	

or Govt Lot #:	Section: 24	Township: 29 N	Range: 7 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves # of

Municipal/Community

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole	Lower Open Bedrock
Rotary - Mud Circulation	
Rotary - Air	
Rotary - Air & Foam	
Drill-Through Casing Hammer	
Reverse Rotary	
Cable-tool Bit ____in. dia...	
Dual Rotary	
Temp. Outer Casing ____in. dia	

Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
30		Surface	48
18		0	50
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
18	SS SCREEN	50	90

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT	Surface	48	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		M	C	SILT @ CLAY	Surface	5
		G		GRAVEL	5	30
		S		SAND	30	40
		G		GRAVEL	40	45
		S		SAND	45	95

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 1100 GP M for 0 Hrs.

Pumping Method ?

11. Well Is

_____ in.
_____Grade

Developed ?

Disinfected ?

Capped ?

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment: PUMP CAPACITY IS 2000 GPM

Created On: 03-09-1999 Updated On: 10-24-2002 Review Status: