

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CA809		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner TOM BURJARSKI PORTSIDE PROPERT						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 59 N 2ND AVE						Town of GARDNER						Street Address or Road Name and Number COUNTY N							
City STURGEON BAY				State WI		Zip Code 54235													
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Door		06-28-1990		00001				00001				00001							
Well Constructor (Business Name) CHARLIES PUMPS AND WD INC				Lic. # 143		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 9504 COUNTY D FORESTVILLE WI 54213				Well Plan Approval #		or Govt Lot # 001		Section 35		Township 27 N		Range 23 E							
				Approval Date (mm-dd-yyyy)		2. Well Type New Well													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2		of previous unique well # constructed in 9											
3. Well serves 1 # of Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No		Reason for replaced or reconstructed well ? NEW HOME													
				Hicap Property ? No															
				Hicap Potable ?															
Construction Type Drilled																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock																
10 Surface 9			Rotary - Mud Circulation																
8 9 112			<u>Yes</u> Rotary - Air																
6 112 573			<u>Yes</u> Rotary - Air & Foam																
Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)			Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...																
			C G			CLAY @ GRAVEL								From (ft.) Surface		To (ft.) 3			
			H			SHALE								3		320			
			L			LIMESTONE								320		573			
			8. Geology																
			6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 34 ft. below ground surface				11. Well Is 14 in. above grade					
6		SAWHILL USA A-53 GR. B API-5L 18.97 WELDED JOINTS21' NEW BLACK 6.625" P.E.				Surface		112											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 100 ft. below surface Pumping at 15 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
6		SAWHILL USA A-53 GR. B API-5L 18.97 WELDED JOINTS21' NEW BLACK 6.625" P.E.				Surface		112											
7. Grout or Other Sealing Material Method WELL SEAL-TREMIE PIPE														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #						Date Signed	
CEMENT GROUT		Surface		112		14													
RM														08-07-1990		08-16-1990			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Foundation Drain to Clearwater		17
			Shoreline/Pool		125

Comment:

Created On: 07-12-1991

Updated On: 07-11-2023

Review Status: