Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CA825

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CY SVATEK	Phone #
Mailing Address: 1362 N 16TH ST	
City: MANITOWOC	State: WI Zip Code: 54220
County: Door	Co. Permit #	Notification #	Completed: 04-17-1990

1. Well Location

Town of GARDNER

Fire # (if avail.)

Street Address or Road Name and Number: DEBROUX RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
CHARLIES PUMPS AND WD INC	143	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

Well Plan Approval #

SW	SE	Section	Township	Range
or Govt Lot #		5	27 N	24 E

Address: 9504 COUNTY D
FORESTVILLE WI 54213

Approval Date (mm-dd-yyyy)

2. Well Type Replacement

of previous unique well # constructed in 90

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

Reason for replaced or reconstructed well ?

LOW WATER

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	13
8	13	134
6	134	685

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 8in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing ____in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	SANDY CLAY	Surface	2
	B	L		BROKEN LIMESTONE	2	4
		L		LIMESTONE	4	12
U		H		SHALE (BLUE)	12	210
T		H		SHALE (BROWN)	210	410
		L		LIMESTONE	410	685

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL U.S.A. A-53 GR. B API-5L 18:97 WELDEDJOINTS 21' NEW BLACK 6 5/8" P.E.	Surface	134
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 7 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT GROUT	Surface	134	12

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
		05-22-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RM		08-27-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Shoreline/Pool		61
			Privy		78

Comment:

Created On: 07-17-1991 Updated On: 07-17-1991 Review Status: