

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CA862		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JEFF PELNER					Phone #		1. Well Location				Fire # (if avail.)						
Mailing Address N7855 CEDAR RD					Town of LINCOLN					Street Address or Road Name and Number CEDAR R:							
City ALGOMA			State WI		Zip Code 54201												
County Kewaunee		Co. Permit #		Notification #		Completed 12-21-1990		Subdivision Name			Lot # Block #						
Well Constructor (Business Name) CHARLIES PUMPS AND WD INC				Lic. # 143		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code						
Address 9504 COUNTY D FORESTVILLE WI 54213				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 27 25 N 24 E		2. Well Type Reconstruction of previous unique well # AW359 constructed in 90									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #			Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ? SAND										
3. Well serves # of Private, potable Heat Exchange ____ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ?												
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		263		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)		L		LIMESTONE		Surface		282			
5		263		282													
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		70 ft. below ground surface				18 in. above grade			
5		SAWHILL USA A53 GR B API-KL 14.62 WELDED JOINTS 21' NEW BLACK 5.562 OD P.E.				Surface		263		10. Pump Test Pumping level 140 ft. below surface Pumping at 20 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
						13. Constructor / Supervisory Driller				Lic #		Date Signed					
												01-08-1991					
						Drill Rig Operator				Lic or Reg #		Date Signed					
						RM						01-08-1991					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 07-15-1991

Updated On: 07-15-1991

Review Status: