

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CC047		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BENSON, MAYNARD						Phone # () 336-8462		1. Well Location				Fire # (if avail.)					
Mailing Address 322 VICTORIA						Town of BARABOO											
City BARABOO						State WI		Zip Code 53913									
County Sauk		Co. Permit #		Notification #		Completed 05-02-1994		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) MARVIN HOLZEM				Lic. # 637		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address N9899 HWY 23 WISCONSIN DELLS WI 53965				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 27 12 N 6 E		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?		NEW HOME									
3. Well serves 1 # of HOME				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled									
Private, potable				Hicap Potable ?													
Heat Exchange ___ # of drillholes																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		72		Yes Rotary - Mud Circulation				P		HARDPAN		Surface		72	
6		72		225		Yes Rotary - Air				Q		QUARTZ		72		225	
						Rotary - Air & Foam											
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		113 ft. below ground surface		15 in. above grade					
6		P.E. NEW PIPE ASTM A53 280 W 18.97 MAVERICK				Surface		72		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 200 ft. below surface		Disinfected ? Yes					
										Pumping at 2 GP M for 4 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method												Filled & Sealed Well(s) as needed?					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		NONE									
DRILLING MUD		Surface		72				13. Constructor / Supervisory Driller									
								Lic #		Date Signed							
								Drill Rig Operator		Lic or Reg #		Date Signed					
								MH				05-09-1994					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Sewer - Building Sanitary		30
Building Overhang		25	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 09-09-1994

Updated On: 09-09-1994

Review Status: