Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CC240

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVID WINKERS			Phone #: (608)943-8087
Mailing Address: 1508 US HWY 18			
City: FENNIMORE	State: WI	Zip Code: 53805	
County: Grant	Co. Permit #:	Notification #:	Completed: 03-14-1990

1. Well Location

Town of WINGVILLE

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): MICHAEL D BEINBORN	Lic. #: 75	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
Address: 501 E OAK ST BOSCOBEL WI 53805-1434		Well Plan Approval #:	Method Code:
Hicap Permanent Well #:	Common Well #:	Approval Date (mm-dd-yyyy):	Specific Capacity: 0.3

SW NE | Section: 21 | Township: 6 N | Range: 1 W
or Govt Lot #:

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of BARN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	211
6	211	320

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		DIRT	Surface	9
	S	H		SOFT SHALE	9	18
	F	L		LIMEROCK @ CREV	18	137
	S	N		SOFT SANDROCK	137	208
		H		SHALE	208	271
	H	N		HARD SAND ROCK	271	320

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STL PL END SAWHILL USA ASTM A53A 6X21#18.97	Surface	211
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

224 ft. below ground surface

10. Pump Test

Pumping level 259 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	211	60

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

USES BOTH

13. Constructor / Supervisory Driller	Lic #	Date Signed
MB		03-31-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MB		03-31-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		260
Building Overhang		12
Fuel Oil Tank	>	100
Barn Gutter		250
Septic or Holding, or POWTS Tank		200

Comment:

Created On: 05-10-1990 Updated On: 05-10-1990 Review Status: