

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CC250		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ORION OLSON						Phone # (608)647-2356		1. Well Location				Fire # (if avail.)							
Mailing Address RR 1 BOX 168						Town of ORION						Street Address or Road Name and Number							
City LONE ROCK				State WI		Zip Code 53581													
County Richland		Co. Permit #		Notification #		Completed 03-29-1990		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) BEINBORN MICHAEL D				Lic. # 75		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address 501 E OAK STREET BOSCOBEL WI 53805				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SW Section Township Range or Govt Lot # 13 9 N 1 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL TIN									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6															
3. Well serves 2 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		46		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 0in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 6in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)		I S H N		DIRT SOFT SHALE SAND ROCK		Surface 19 26 26		19 26 80					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				12 in. above grade					
6		NEW BLK STL PL END A-53A ASTM SAWHILL USA 21X618.97				Surface		46		10. Pump Test Pumping level 53 ft. below surface Pumping at 10 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method TREMIE												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT				Surface		46		12											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												MB						04-12-1990	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												MB						04-12-1990	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Building Overhang		30
			Septic or Holding, or POWTS Tank		81

Comment:

Created On: 05-10-1990

Updated On: 10-24-2002

Review Status: