Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CC250

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ORION OLSON			Phone #: (608)647-2356
Mailing Address: RR 1 BOX 168			
City: LONE ROCK	State: WI	Zip Code: 53581	
County: Richland	Co. Permit #:	Notification #:	Completed: 03-29-1990

Well Constructor (Business Name): BEINBORN MICHAEL D	Lic. #: 75	Facility ID # (Public Wells):	
Address: 501 E OAK STREET BOSCOBEL WI 53805		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6	

3. Well serves 2 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ORION

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code
SE SW or Govt Lot #	Section: 13	Township: 9 N	Range: 1 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL TIN

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	46
6	46	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit 0in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 6in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		DIRT	Surface	19
	S	H		SOFT SHALE	19	26
		N		SAND ROCK	26	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STL PL END A-53A ASTM SAWHILL USA 21X618.97	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	46	12

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 53 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MB		04-12-1990
Drill Rig Operator	Lic or Reg #	Date Signed
MB		04-12-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95

Type	Qualifier	Distance
Building Overhang		30
Septic or Holding, or POWTS Tank		81

Comment:

Created On: 05-10-1990 Updated On: 10-24-2002 Review Status: