Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CC252

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEORGE OLSON			Phone #: (608)654-5156
Mailing Address: RR 3 BOX 12			
City: CASHTON	State: WI	Zip Code: 54619	
County: Monroe	Co. Permit #:	Notification #:	Completed: 04-23-1990

Well Constructor (Business Name): BEINBORN MICHAEL D	Lic. #: 75	Facility ID # (Public Wells):	
Address: 501 E OAK STREET BOSCOBEL WI 53805		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2	

3. Well serves 1 # of BARN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of PORTLAND

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #	Section: 36	Township: 15 N	Range: 4 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD TIN CASE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	197
6	197	240

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I	B		DIRT @ LOOSE ROCK	Surface	61
F	L			LIME ROCK @ CREVICE	61	169
S	N			SOFT SAND ROCK	169	192
H	N			HARD SAND ROCK	192	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STL PL END SAWHILL USA ASTM A-5A 18.976X21 .280W	Surface	197
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	197	62

9. Static Water Level
152 ft. below ground surface

10. Pump Test
Pumping level 194 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. below grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
DON HEHN WILL ABONDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
MDB		05-08-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MDB		05-08-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Barn Gutter		120

Comment:

Created On: 06-06-1990 Updated On: 06-06-1990 Review Status: