Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CC254

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	ALOIS KIRSCHBAUM
Phone #	(608)794-2539
Mailing Address	7577 PRIDE RD
City	GLEN HAVEN
State	WI
Zip Code	53810
County	Grant
Co. Permit #	
Notification #	
Completed	04-30-1990
Well Constructor (Business Name)	BEINBORN MICHAEL D
Lic. #	75
Facility ID # (Public Wells)	
Address	501 E OAK STREET BOSCOBEL WI 53805
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.5

1. Well Location

Town of W GLEN HAVEN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.78102 °N	-91.01774 °W			GPS008

SE	NE	Section	Township	Range
or Govt Lot #		36	4 N	6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NOT ENOUGH WATER

Construction Type Drilled

3. Well serves 1 # of BARN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	126
6	126	200

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Yes Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit 0in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	B	CLAY @ LOOSE ROCK	Surface	56
	F	L		LIME ROCK @ CREVICE	56	116
		L		LIME ROCK	116	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END SAWHILL USA ASTM A-53A18.97 .280W 6X21	Surface	126
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	126	38

9. Static Water Level

128 ft. below ground surface

10. Pump Test

Pumping level 149 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OLD WELL FOR CATTLE TANK

13. Constructor / Supervisory Driller	Lic #	Date Signed
MDB		05-08-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MDB		05-08-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Barn Gutter		110
Building Overhang		15	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 06-06-1990 Updated On: 08-16-2022 Review Status: