Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CC972

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CLARK, MARK	Phone #: (414)867-3240
Mailing Address: STAR RT BOX 29A	
City: WEYAUWEGA	State: WI — Zip Code: 54983
County: Winnebago	Co. Permit #: — Notification #: — Completed: 12-01-1990
Well Constructor (Business Name): VALLEY WELL DRILLING INC	Lic. #: 328 — Facility ID # (Public Wells):
Address: N1600 HWY 10 S, WEYAUWEGA WI 54983	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 15

1. Well Location

Town of WOLF RIVER			Fire # (if avail.): 7785
Street Address or Road Name and Number: 7785 BAY LN			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.1729 °N -88.8405 °W			Method Code: GCD013
SW SW or Govt Lot #	Section: 28	Township: 20 N	Range: 14 E

2. Well Type Replacement
of previous unique well # — constructed in
Reason for replaced or reconstructed well ? UPDATED OLD 2 INCH
Construction Type: Drilled

3. Well serves 1 # of NONE
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	132

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	15
		Z	G	CLAY GRAVEL @ STONES	15	35
		Z	S	SANDY CLAY GAVEL	35	57
		C	S	SANDY CLAY	57	72
		N		SANDSTONE	72	132

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 1945 PR FT A53 GRB USPCO T@C	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method CLAY SLURRY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRAVITY CLAY SL	Surface	20	

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 6 ft. below surface
Pumping at 15 GP M for 72 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
		12-01-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
NDL		12-01-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		6

Comment:

Created On: 02-24-1995 Updated On: 10-18-2019 Review Status: