Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CD003

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ERNEST SANDMAN	Phone #: (608)326-3676
Mailing Address: W7755 A JOHNSON RD	
City: HOLMEN	State: WI — Zip Code: 54636
County: La Crosse	Co. Permit #: W01343 — Notification #: — Completed: 01-19-1989
Well Constructor (Business Name): STAUFFER RICHARD H	Lic. #: 231 — Facility ID # (Public Wells):
Address: N5254 HWY 53 ONALASKA WI 54650	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7.5

1. Well Location

Town of HOLLAND

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SE — Section: 11 — Township: 18 N — Range: 8 W

or Govt Lot #:

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

PLUGGED 2" POINT

Construction Type: Drilled

3. Well serves 2 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	106
6	106	117

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	G	SAND @ GRAVEL	Surface	65
		S		SAND	65	105
		N		SANDSTONE	105	117

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.63	O.D. NEW-BLACK-P.E. STEEL WELD-.280 WHL-18.97#ASTM-A53-A TIAWAN	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

78 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP for 3 Hrs.

Pumping Method ?

11. Well Is

10 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL MUD	Surface	106	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
		01-25-1989
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RO		01-24-1989

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		19
Downspout/Yard Hydrant		23
Nonconforming Pit or Alcove		21
Privy		73
Sewer - Building Sanitary		52
Septic or Holding, or POWTS Tank		57

Comment:

Created On: 11-29-1989 Updated On: 11-29-1989 Review Status: