

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CD003		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner ERNEST SANDMAN						Phone # (608)326-3676		1. Well Location				Fire # (if avail.)		
Mailing Address W7755 A JOHNSON RD						Town of HOLLAND						Street Address or Road Name and Number		
City HOLMEN				State WI		Zip Code 54636								
County La Crosse		Co. Permit # W01343		Notification #		Completed 01-19-1989		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) STAUFFER RICHARD H				Lic. # 231		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address N5254 HWY 53 ONALASKA WI 54650				Well Plan Approval #		NE SE		Section 11		Township 18 N		Range 8 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Range 8 W						
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5		2. Well Type Replacement of previous unique well # constructed in								
3. Well serves 2 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No		Reason for replaced or reconstructed well ? PLUGGED 2" POINT								
				Hicap Property ? No										
				Hicap Potable ?										
Construction Type Drilled														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
8		Surface		106		Yes Rotary - Mud Circulation				Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				
6		106		117										
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
S G				SAND @ GRAVEL				Surface		65				
S				SAND				65		105				
N				SANDSTONE				105		117				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6.63		O.D. NEW-BLACK-P.E. STEEL WELD-.280 WHL-18.97#ASTM-A53-A TIWAN				Surface		106						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
DRILL MUD				Surface		106								
9. Static Water Level														
78 ft. below ground surface														
10. Pump Test														
Pumping level 80 ft. below surface														
Pumping at 15 GP for 3 Hrs.														
Pumping Method ?														
11. Well Is														
10 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller										Lic #		Date Signed		
												01-25-1989		
Drill Rig Operator										Lic or Reg #		Date Signed		
RO												01-24-1989		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Nonconforming Pit or Alcove		21
Building Overhang		19	Privy		73
Downspout/Yard Hydrant		23	Sewer - Building Sanitary		52
			Septic or Holding, or POWTS Tank		57

Comment:

Created On: 11-29-1989

Updated On: 11-29-1989

Review Status: