Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CE506

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOBY SCHLICH	Phone #: (414)868-3769
Mailing Address: BOX 331	
City: FISH CREEK	State: WI — Zip Code: 54212
County: Door	Co. Permit #: — Notification #: — Completed: 11-15-1990
Well Constructor (Business Name): JORNS ERWIN	Lic. #: 443 — Facility ID # (Public Wells):
Address: P O BOX 44, EGG HARBOR WI 54209	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.3

1. Well Location

Town of GIBRALTER

Fire # (if avail.):

Street Address or Road Name and Number: SUGAR BUSH RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SW or Govt Lot #: — Section: 36 — Township: 31 N — Range: 27 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
8	10	173
6	173	223

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	GROUND	Surface	3
L	LIMEROCK	3	223

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STAND BLACK STEEL P/E 18.97# ASTM A53 GRADE BLTV STEEL	Surface	173
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

82 ft. below ground surface

10. Pump Test

Pumping level 85 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	173	75

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJ		12-17-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JJ		12-17-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		10
			Septic or Holding, or POWTS Tank		40

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	01/13/2017	3/8" BENTONITE CHIPS 0-223' 61 SACKS	WELL IN WAY OF ADDITION

Created On: 04-03-1991 Updated On: 01-17-2017 Review Status: