Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CE545

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GREGORY SWAIN	Phone #: (414)854-2530
Mailing Address: 403 BLUFFSIDE LN	
City: SISTER BAY	State: WI — Zip Code: 54234
County: Door	Co. Permit #: — Notification #: — Completed: 05-19-1992
Well Constructor (Business Name): ERWIN JORNS	Lic. #: 443 — Facility ID # (Public Wells):
Address: PO BOX 44, EGG HARBOR WI 54209-0044	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.1	

1. Well Location

Town of GIBRALTAR — Fire # (if avail.):

Street Address or Road Name and Number: COUNTY EE

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SE or Govt Lot #: — Section: 16 — Township: 30 N — Range: 27 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	11
8	11	173
6	173	242

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY @ STONES	Surface	3
		L		LIMESTONE	3	242

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END 18.97# ASTM A53-GR. BSAWHILL TUBULAR	Surface	173
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	173	70 S

9. Static Water Level

43 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJ		06-25-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JJ		06-25-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 09-30-1992 Updated On: 10-04-2004 Review Status: