

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CE591		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner TOM STAVER						Phone # (414)868-3711		1. Well Location				Fire # (if avail.)			
Mailing Address 7960 EGG HARBOR RD						Town of EGG HARBOR						Street Address or Road Name and Number			
City EGG HARBOR						State WI		Zip Code 54209				CHERRY BLUFF			
County		Co. Permit #		Notification #		Completed 10-30-1990		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) JORNS ERWIN						Lic. # 443		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)		Method Code	
Address P O BOX 44 EGG HARBOR WI 54209						Well Plan Approval #		SW NW		Section 19		Township 30 N		Range 27 E	
								or Govt Lot #		19		30 N		27 E	
Approval Date (mm-dd-yyyy)						2. Well Type New Well						of previous unique well #		constructed in	
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3				Reason for replaced or reconstructed well ?					
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes						Hicap Property ? No									
Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 10			Rotary - Mud Circulation												
8 10 177			Yes Rotary - Air												
6 177 243			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ___ in. dia												
			Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
I				GROUND				Surface		2					
L				LIMEROCK				2		243					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW STAND BLACK STEEL P/E 18.97# ASTM A53 GRADE BLTV STEEL				Surface		177							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		177		80							
9. Static Water Level															
118 ft. below ground surface															
10. Pump Test															
Pumping level 126 ft. below surface															
Pumping at 10 GP for 1 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
EJ				12-17-1990											
Drill Rig Operator				Lic or Reg #											
JJ				12-17-1990											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-03-1991

Updated On: 04-03-1991

Review Status: