Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CE591

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOM STAVER			Phone #: (414)868-3711
Mailing Address: 7960 EGG HARBOR RD			
City: EGG HARBOR	State: WI	Zip Code: 54209	
County: Door	Co. Permit #:	Notification #:	Completed: 10-30-1990

1. Well Location

Town of EGG HARBOR

Fire # (if avail.):

Street Address or Road Name and Number: CHERRY BLUFF

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JORNS ERWIN	443	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

Well Plan Approval #:

SW	NW	Section	Township	Range
or Govt Lot #		19	30 N	27 E

Address: P O BOX 44
EGG HARBOR WI 54209

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.3

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
8	10	177
6	177	243

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	GROUND	Surface	2
L	LIMEROCK	2	243

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STAND BLACK STEEL P/E 18.97# ASTM A53 GRADE BLTV STEEL	Surface	177
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

118 ft. below ground surface

10. Pump Test

Pumping level 126 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	177	80

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJ		12-17-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JJ		12-17-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-03-1991 Updated On: 04-03-1991 Review Status: