Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CE599

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STEVE JACOBS			Phone #: (312)649-0272
Mailing Address: 1846 N HOWE ST			
City: CHICAGO	State: IL	Zip Code: 60614	
County: Door	Co. Permit #:	Notification #:	Completed: 11-10-1990

1. Well Location

Town of GIBRALTAR

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #
WILD FLOWER PATCH	00025	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JORNS ERWIN	443	

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code

Well Plan Approval #

SE	SW	Section	Township	Range
or Govt Lot #		18	30 N	27 E

Address: P O BOX 44
EGG HARBOR WI 54209

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.1

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
8	10	198
6	198	262

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	GROUND	Surface	3
L	LIMEROCK	3	262

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STAND BLACK STEEL P/E 18.97# ASTM A53 GRADE BLTV STEEL	Surface	198
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

158 ft. below ground surface

10. Pump Test

Pumping level 167 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

10 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	198	60

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJ		12-17-1990
Drill Rig Operator	Lic or Reg #	Date Signed
JJ		12-17-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Septic or Holding, or POWTS Tank		27

Comment:

Created On: 04-03-1991 Updated On: 04-03-1991 Review Status: