

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CE599		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner STEVE JACOBS						Phone # (312)649-0272		1. Well Location				Fire # (if avail.)							
Mailing Address 1846 N HOWE ST						Town of GIBRALTAR						Street Address or Road Name and Number							
City CHICAGO				State IL		Zip Code 60614													
County		Co. Permit #		Notification #		Completed 11-10-1990		Subdivision Name WILD FLOWER PATCH				Lot # 00025		Block #					
Well Constructor (Business Name) JORNS ERWIN				Lic. # 443		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address P O BOX 44 EGG HARBOR WI 54209				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 18 30 N 27 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		10		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)		I		GROUND				Surface		3			
8		10		198				L		LIMEROCK		3		262					
6		198		262				6. Casing, Liner, Screen		9. Static Water Level		11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)						To (ft.)		158 ft. below ground surface		10 in. above grade					
6		NEW STAND BLACK STEEL P/E 18.97# ASTM A53 GRADE BLTV STEEL		Surface		198		10. Pump Test		Developed ? Yes									
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)		Pumping level 167 ft. below surface		Disinfected ? Yes									
Pumping at 10 GP for 1 Hrs.		Pumping Method ?		Capped ? Yes		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes													
7. Grout or Other Sealing Material		Method TREMIE		Kind of Sealing Material								From (ft.)		To (ft.)		# Sacks Cement			
NEAT CEMENT		Surface		198								60							
13. Constructor / Supervisory Driller		Lic #		Date Signed		EJ Drill Rig Operator Lic or Reg # Date Signed JJ 12-17-1990													
EJ		12-17-1990																	
JJ		12-17-1990																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Septic or Holding, or POWTS Tank		27

Comment:

Created On: 04-03-1991

Updated On: 04-03-1991

Review Status: