

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CE600		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner KATHLEEN ROHRER						Phone # (414)823-2457		1. Well Location				Fire # (if avail.)													
Mailing Address 6661 HWY 57						Town of JACKSONPORT						Street Address or Road Name and Number													
City BAILEYS HARBOR				State WI		Zip Code 54202																			
County		Co. Permit #		Notification #		Completed 11-03-1990		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) JORNS ERWIN						Lic. # 443		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address P O BOX 44 EGG HARBOR WI 54209						Well Plan Approval #				°N		°W		NE NE Section Township Range or Govt Lot # 14 29 N 27 E											
						Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #				Common Well #		Specific Capacity 1.7				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?															
3. Well serves 1 # of Private,potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method														8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
10		Surface		35		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)				S				SAND				Surface		27					
8		35		148						C G				CLAY AND STONES				27		35					
6		148		203						L				LIMEROCK				35		203					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly								From (ft.)		To (ft.)		42 ft. below ground surface				18 in. above grade							
6		NEW STAND BLACK STEEL P/E 18.97# ASTM A53 GRADE BLTV STEEL				Surface		148		10. Pump Test Pumping level 48 ft. below surface Pumping at 10 GP for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																	
7. Grout or Other Sealing Material Method TREMIE														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement																	
NEAT CEMENT				Surface		148		75																	
13. Constructor / Supervisory Driller														Lic #				Date Signed							
														EJ				12-17-1990							
														Drill Rig Operator				Lic or Reg #				Date Signed			
														JJ				12-17-1990							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		14
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 04-03-1991

Updated On: 04-03-1991

Review Status: