

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CE970		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																																
Property Owner IVAN DONCHEFF						Phone #		1. Well Location				Fire # (if avail.)																														
Mailing Address 3121 W 98						Town of ELK						Street Address or Road Name and Number																														
City EVERGREEN PARK				State IL		Zip Code 60642																																				
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #																												
Price						11-10-1990																																				
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code																												
DAVIS DAVID				642						°N		°W																														
Address HCR3 BOX 42 PHILLIPS WI 54555				Well Plan Approval #		SW		SW		Section		Township		Range																												
				Approval Date (mm-dd-yyyy)		or Govt Lot #		15		37 N		1 W																														
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type Replacement																																
						1.3				of previous unique well #				constructed in																												
3. Well serves 1 # of				Hicap Well ?		No				Reason for replaced or reconstructed well ? WATER SHORTAGE																																
Private, potable				Hicap Property ?		No																																				
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled																																				
4. Potential Contamination Sources - ON REVERSE SIDE																																										
5. Drillhole Dimensions and Construction Method																																										
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole					Lower Open Bedrock																												
10			Surface			20			Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)																																	
6			20			35																																				
8. Geology																																										
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)																														
R				C				RED CLAY				Surface				18																										
				S				SAND				18				32																										
				S G				SAND - GRAVEL - ROCKS				32				35																										
6. Casing, Liner, Screen														9. Static Water Level														11. Well Is														
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)			To (ft.)			18.5 ft. below ground surface														12 in. above grade													
6			BLK STEEL 18.97 P.E. SUMITOMO A53						Surface			35			10. Pump Test Pumping level 26 ft. below surface Pumping at 10 GP for 4 Hrs. Pumping Method ?														Developed ? Yes Disinfected ? Yes Capped ? Yes													
Dia. (in.)			Screen type, material & slot size						From (ft.)			To (ft.)																														
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?																												
Method														Filled & Sealed Well(s) as needed? Yes																												
Kind of Sealing Material						From (ft.)			To (ft.)			# Sacks Cement																														
PUDDLE CLAY						Surface			20																																	
DD														13. Constructor / Supervisory Driller														Lic #				Date Signed										
														Drill Rig Operator														Lic or Reg #				Date Signed										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		58	Sewer - Building Sanitary		37
Building Overhang		13	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 06-19-1990

Updated On: 06-19-1990

Review Status: