Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CE970

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: IVAN DONCHEFF			Phone #
Mailing Address: 3121 W 98			
City: EVERGREEN PARK	State: IL	Zip Code: 60642	
County: Price	Co. Permit #	Notification #	Completed: 11-10-1990

Well Constructor (Business Name): DAVIS DAVID	Lic. #: 642	Facility ID # (Public Wells)	
Address: HCR3 BOX 42 PHILLIPS WI 54555		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.3	

1. Well Location

Town of ELK

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name		Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code	
SW SW or Govt Lot #	Section: 15	Township: 37 N	Range: 1 W	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

WATER SHORTAGE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	35

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		RED CLAY	Surface	18
		S		SAND	18	32
		S	G	SAND - GRAVEL - ROCKS	32	35

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK STEEL 18.97 P.E. SUMITOMO A53	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

18.5 ft. below ground surface

10. Pump Test

Pumping level 26 ft. below surface

Pumping at 10 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLE CLAY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		01-19-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		58
Building Overhang		13

Type	Qualifier	Distance
Sewer - Building Sanitary		37
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 06-19-1990 Updated On: 06-19-1990 Review Status: