Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF340

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NIKE TUNER			Phone #: (715)824-2868
Mailing Address: 10217 HWY B			
City: AMHERST	State: WI	Zip Code: 51406	
County: Portage	Co. Permit #:	Notification #:	Completed: 04-04-1990

Well Constructor (Business Name): MAVES LEONARD K	Lic. #: 190	Facility ID # (Public Wells):	
Address: 4347 KUBISIAK DR AMHERST WI 54406		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

3. Well serves 1 # of BARN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of AHMERST

Fire # (if avail.):

Street Address or Road Name and Number: 10217 HWY B

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW SE or Govt Lot #:	Section: 22	Township: 23 N	Range: 10 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW WELL FOR GRADE A

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	107

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S	G	SAND AND GRAVEL C BR SOFT	Surface	70
	V	X	G	CLAY SAND GRAVEL NC GR SOFT	70	101
	Q	S	G	SAND AND GRAVEL C BR SOFT	101	107

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL NEWPORT WELDED ASTM A53 18.97# FT1780 LBS	Surface	103
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	X4X20 SLOT STAINLESS SCREEN	103	107

7. Grout or Other Sealing Material
Method

9. Static Water Level
70 ft. below ground surface

10. Pump Test
Pumping level 76 ft. below surface
Pumping at 15 GP for 24 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
2" WELL STILL BEING USED

13. Constructor / Supervisory Driller	Lic #	Date Signed
LM		04-17-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Silo/Storage Tube	>	100
Building Drain - Sanitary		60	Barn Gutter		90
Building Overhang		88	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 05-17-1990 Updated On: 05-17-1990 Review Status: