Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF341

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEVIN CHOJNECKI			Phone #: (715)341-1548
Mailing Address: 5600 PRAIRIE AVE			
City: STEVENS POINT	State: WI	Zip Code: 54481	
County: Portage	Co. Permit #:	Notification #:	Completed: 04-17-1990

1. Well Location

Town of HULL

Fire # (if avail.):

Street Address or Road Name and Number: 5600 PRAIRIE DR

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MAVES LEONARD K	190	

Latitude / Longitude in Decimal Degree (DD): 44.5871 °N -89.5109 °W

Method Code: GCD013

SE	SE	Section	Township	Range
or Govt Lot #		2	24 N	8 E

Well Plan Approval #:

Address: 4347 KUBISIAK DR
AMHERST WI 54406

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

Reason for replaced or reconstructed well ?: NEW HOUSE

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 8in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		SAND C BR SOFT	Surface	8
	V	C		CLAY NC GR SOFT	8	11
P		Q		GRANITE PINK	11	75
R		Q		GRANITE RED	75	104

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL TEX TUBE WELDED A53B 2220 PSI18.97# FT	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 10 GP for 12 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	6

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LM		04-17-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Privy		60

Comment:

Created On: 05-17-1990 Updated On: 05-07-2020 Review Status: