Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF374

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WILLIAM FROELICH	Phone #: (715)366-2845
Mailing Address: R 2 BOX 105	
City: PLAINFIELD	State: WI Zip Code: 54966
County: Waushara	Co. Permit #:
Notification #	Completed: 08-16-1990
Well Constructor (Business Name): PETRICK ROBERT	Lic. #: 125
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 3663 GRAY LOG LANE STEVENS POINT WI 54481	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 7.5	

1. Well Location

Town of OASIS

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.21209 °N -89.41326 °W	GPS008

NE NE or Govt Lot #	Section	Township	Range
	15	20 N	9 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NO WATER-TABLE DROPPED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	113

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I			TOPSOIL	Surface	2
N	S	G		FINE SAND @ GRAVEL	2	80
A	S	G		COURSE SAND @ GRAVEL	80	117

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SAWHILL ASTMA 529# .237 WALL 11 LB. PF. T@C.	Surface	113
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.9	HOWARD SMITH (SS)	113	117

9. Static Water Level

77 ft. below ground surface

10. Pump Test

Pumping level 79 ft. below surface

Pumping at 15 GP for 13 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

HE IS

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP		08-27-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		30
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-22-1991 Updated On: 09-08-2022 Review Status: