Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF381

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOE MILER			Phone #
Mailing Address: RT 1			
City: COLOMA	State: WI	Zip Code: 54930	
County: Waushara	Co. Permit #	Notification #	Completed: 10-04-1990

Well Constructor (Business Name): PETRICK ROBERT	Lic #: 125	Facility ID # (Public Wells)	
Address: 3663 GRAY LOG LANE STEVENS POINT WI 54481		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 7.5	

1. Well Location

Town of RICHFORD

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code
SE NE or Govt Lot #	Section: 35	Township: 18 N	Range: 9 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	90

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	3
		S	G	SAND AND GRAVEL	3	95

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SAWHILL ASTMA 589# .237 WALL 11LB PF T@C	Surface	90
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.9	HOWARD SMITH	90	95

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 77 ft. below surface

Pumping at 15 GP for 8 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP		10-05-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 02-22-1991 Updated On: 02-22-1991 Review Status: