Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF382

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICK MASLOWSKI	Phone #: (715)824-5572
Mailing Address: 8088 STANDING ROCKS	
City: MAHERST	State: WI Zip Code: 54406
County: Portage	Co. Permit #:
Notification #:	Completed: 08-21-1990
Well Constructor (Business Name): PETRICK ROBERT	Lic. #: 125
Facility ID # (Public Wells):	
Address: 3663 GRAY LOG LANE STEVENS POINT WI 54481	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 7.5	

1. Well Location

Town of STOCKTON

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: Lot #: Block #:

Latitude / Longitude in Decimal Degree (DD): 44.4335 °N -89.38132 °W

Method Code: GPS008

NE NW or Govt Lot #: Section: 35 Township: 23 N Range: 9 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	118

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I			TOP SOIL	Surface	3
	S			SAND	3	26
	C	M		CLAY SLOP	26	78
N	S			FINE SAND	78	100
	S	G		SAND AND GRAVEL	100	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SAWHILL ASTMA 529II .237 WALL 11LB PF T@C	Surface	118
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.9	HOWARD SMITH	118	123

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 15 GP for 10 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP		09-05-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-22-1991 Updated On: 08-17-2022 Review Status: