Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF894

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JESSIE SMITH			Phone #: (715)866-7155
Mailing Address: 7667 CO FF			
City: WEBSTER	State: WI	Zip Code: 54893	
County: Burnett	Co. Permit #:	Notification #:	Completed: 04-08-1992

Well Constructor (Business Name): BEECROFT, GARY	Lic. #: 137	Facility ID # (Public Wells):	
Address: 1318 350TH AVE SIREN WI 54872-9604		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): 7667

Town of MEENON

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NE SW or Govt Lot #:	Section: 8	Township: 39 N	Range: 16 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	55.33

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	7
S	SAND	7	17
Y	SAND @ GRAVEL	17	42
S	SAND	42	54.33

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL 10.79# PER FT ASTM A53 .237 WALLTHICKNESS SAWHILL PIPE CO WELDED JOINTS	Surface	51.33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STEEL SCREEN 8 SLOT STAINLESS	50.83	55.33

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CLUMBLES WHILE DRIVING PIPE	Surface	0	

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 20 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		05-13-1992
Drill Rig Operator	Lic or Reg #	Date Signed
GB		05-13-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: