

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CF894		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner JESSIE SMITH					Phone # (715)866-7155			1. Well Location				Fire # (if avail.)									
Mailing Address 7667 CO FF					Town of MEENON					7667											
City WEBSTER					State WI		Zip Code 54893					Street Address or Road Name and Number									
County Burnett		Co. Permit #		Notification #			Completed 04-08-1992			Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) BEECROFT, GARY					Lic. # 137		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)			Method Code								
Address 1318 350TH AVE SIREN WI 54872-9604					Well Plan Approval #			NE SW		Section 8		Township 39 N		Range 16 W							
Hicap Permanent Well #					Common Well #		Specific Capacity 2.5			2. Well Type New Well											
Heat Exchange ___ # of drillholes					Hicap Well ? No			of previous unique well # constructed in													
Private, potable					Hicap Property ? No			Reason for replaced or reconstructed well ?													
Hicap Potable ?					Construction Type Drilled			HOME													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock											
4		Surface		55.33		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				8. Geology											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
4		NEW BLACK STEEL 10.79# PER FT ASTM A53 .237 WALLTHICKNESS SAWHILL PIPE CO WELDED JOINTS				Surface		51.33		C		CLAY		Surface		7					
4		STEEL SCREEN 8 SLOT STAINLESS				50.83		55.33		S		SAND		7		17					
4		STEEL SCREEN 8 SLOT STAINLESS				50.83		55.33		Y		SAND @ GRAVEL		17		42					
4		STEEL SCREEN 8 SLOT STAINLESS				50.83		55.33		S		SAND		42		54.33					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				12 in. above grade							
4		NEW BLACK STEEL 10.79# PER FT ASTM A53 .237 WALLTHICKNESS SAWHILL PIPE CO WELDED JOINTS				Surface		51.33		10. Pump Test				Developed ? Yes							
4		STEEL SCREEN 8 SLOT STAINLESS				50.83		55.33		Pumping level 45 ft. below surface				Disinfected ? Yes							
4		STEEL SCREEN 8 SLOT STAINLESS				50.83		55.33		Pumping at 20 GP for 1 Hrs.				Capped ? Yes							
4		STEEL SCREEN 8 SLOT STAINLESS				50.83		55.33		Pumping Method ?				12. Notified Owner of need to fill & seal ?							
7. Grout or Other Sealing Material														Filled & Sealed Well(s) as needed?							
Method														13. Constructor / Supervisory Driller				Lic #		Date Signed	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		GB				05-13-1992		Drill Rig Operator		Lic or Reg #		Date Signed			
BENTONITE CLUMBLES WHILE DRIVING PIPE		Surface		0		0		GB				05-13-1992		GB		05-13-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: