Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF897

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT GUNDERSHAUG			Phone #: (612)537-2608
Mailing Address: 6260 BOONE AVE N			
City: BROOKLYN PARK	State: MN	Zip Code: 55428	
County: Burnett	Co. Permit #:	Notification #:	Completed: 04-16-1992
Well Constructor (Business Name): BEECROFT, GARY	Lic. #: 137	Facility ID # (Public Wells):	
Address: 1318 350TH AVE SIREN WI 54872-9604		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.2	

1. Well Location

Town of UNION

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NE	NW	Section	Township	Range
or Govt Lot #		26	40 N	17 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: TO REPLACE SAND POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	57.17

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	7
		C		CLAY	7	17
		Y	U	MUDDY SAND @ GRAVEL	17	32
		S		SAND	32	57.17

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL 10.79# PER FT. ASTM A53 .237 WALLTHICKNESS SAWHILL PIPE CO. WELDED JOINTS	Surface	53.17
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STEEL SCREEN 10 SLOT STAINLESS	52.67	57.17

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANUELS WHILE DRIVING PIPE	Surface	0	

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 47 ft. below surface

Pumping at 20.1 GP for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OWNER WILL SEAL IT

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		05-19-1992
Drill Rig Operator	Lic or Reg #	Date Signed
GB		05-19-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90

Type	Qualifier	Distance
Building Overhang		17
Septic or Holding, or POWTS Tank		57

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: